

RANCHI MUNICIPAL CORPORATION, RANCHI


Ref No.: THSSS/10/23

Date: 10.04.2023

I inspected the Tender Heart Senior Secondary School, Tupudana, P.O. Hatia, District Ranchi on 10.04.2023. The following Health and sanitation conditions and others were observed in the school.

1. Building Safety.	Found satisfactory. Railing and parapet walls up to a height of 3' - 00" have been provided in verandah, balconies, staircase and roof top. Safety grills have been provided in windows and others openings.
2. Fire safety.	Fire extinguishers are available in sufficient numbers.
3. Drinking water facility.	Having deep boring and one well along with 1.5 HP pump with a 62 KVA generator in addition to the electric power supply to lift the water from deep well to store in the overhead water tanks. Sufficient nos. of water taps connected with Aquaguard filtration plants is provided for filtered water being supplied to the student for drinking purpose. The water is supplied for gardening and in toilets as well.
4. Health and Sanitary Condition.	Septic tanks and main wholes have been made as per requirements. Adequate no. of water coolant sets and urinals. Pucca drain has been also been provided for boys and girls. The school have a beautiful lawn in front of the Main Building which adds aesthetic value to the children.

Overall, the facilities mentioned above in the school in the building and campuses are found in good conditions.


निर्मला कच्छप (गाड़ी)
पार्षद
वार्ड नं०-53
राँची नगर निगम, राँची

Nirmala Kachhap (Gari)

Ward Commissioner

Ward No. - 55 / 53

RMC, Ranchi, Jharkhand.